



AVAYO ELECTRONICS CANADA CORPORATION

Fire Test Report



FIRE TESTING LABORATORIES, INC.

Testing & Listing
Engineering & Consulting Services

Field Labeling

Page 1 of 9
GL 12412

Guardian Fire Testing Laboratories, Inc.
15 Wenonah Terr. (Office)
Tonawanda, NY 14150-7027

Office Phone: 716 835 6880 Fax: 716 835 5682
Lab Phone: 716 877 2760
Email: gftli@earthlink.net
Web Site: www.firetesting.com

480 Hinman (Lab)
Buffalo, NY 14216-1019

FIRE TEST REPORT: 3 Hour Floor Assembly with AVAYO Raised Access Floor System

CLIENT/MFG: AVAYO Electronics Canada Corporation
557 North 10th St.
Blytheville, Arkansas 72315

MODEL, NAME & NUMBER: AVAYO Raised Access Floor System
Floor Panel Size: 600 X 600 X 35MM., Riser - 20 inches

STANDARDS TESTED TO: ASTM E-119-11a Floor/Ceiling; NFPA 251; UL 263, Small Scale
Test; CAN/ULC-S-101-07 With No Load Capacity.

REPORT NO: GL12412


TEST DATE: 1/20/12

REPORT DATE: 2/3/12

TEST RESULTS: Test met the intent of the test standard for a 3-hour fire rating with no load.

**TEST PERFORMED AND
REPORT PREPARED BY:** GUARDIAN FIRE TESTING LABORATORIES, INC.
480 Hinman Ave.
Buffalo, NY 14216-1019

This test is accredited and meets the requirements of ISO/IEC 17025 as verified by ANSI/ASQ National Accreditation Board/ACLASS. Refer to certificate and scope of accreditation Report AT 1247.


R. Joseph Pearson
Fire Test Engineer
2/7/12